Australia and New Zealand Certificate of Suitability

Certificate
ULL-104526

Issue date
2026-06-10

Expiration date
2031-06-10

This is to acknowledge that

Signify Netherlands B.V.

High Tech Campus 48, EINDHOVEN 5656 AE
Netherlands

has had

Electronic controlgear for LED modules

[refer following page(s) for models list]

evaluated and meets the requirements of the standard(s)

AS 61347.2.13:2018; AS/NZS 61347.1:2016, Amd 1: 2018, Amd 2: 2025

ANZ Certification Scheme requirements.

Stuart Foster (Certification Officer)

Certification Body:
UL International New Zealand Limited,
54 Tarndale Grove, Albany, Auckland 0632, New Zealand.

Issued for use in Australia and New Zealand only.
All dates are in Year-Month-Day format (YYYY-MM-DD).

JAS-ANZ

www.jasanz.org/register

UL Solutions

© 2026 UL LLC. All rights reserved.

Australia and New Zealand
Certificate of Suitability

Certificate No: ULL-104526
Date of Issue/Revision: 2026-06-10

Trade Name or Trademark: PHILIPS, SIGNIFY, XITANIUM, ADVANCE

Risk Class / NSW Declared Class: EESS OUT OF SCOPE - Non-prescribed / non-declared

IEC Standard Country Differences: AU and NZ

Certification Marking: The RCM may be applied to the product and all the requirements of all relevant parts of AS/NZS 4417 applicable to the article shall be fulfilled.

Additional Certification Conditions: Product is a component for building in.

Model Details and Additional Information:
Rating :
Xitanium 75W 0.7-2.0A 54V TD 230V G2
Pin: 83 W, Uin: 220-240 Vac, Iin: 0.38 Aac, Uin: 186-250 Vdc,
Iin: 0.45 Adc, fn: 50/60 Hz, DC, PF: 0.9C,
Prated: 75 W, Uoutput: 27-54 Vdc. Uout: 60 Vmax, Irated: 0.7-2 A,
tc(max): 75 °C, ta: -25 … +50 °C,
built-in, SELV

Xitanium 36W 0.3-1.0A 54V TD 230V G2
Pin: 41 W, Uin: 220-240 Vac, Iin: 0.19 Aac, Uin: 186-250 Vdc,
Iin: 0.22 Adc, fn: 50/60 Hz, DC, PF: 0.9C,
Prated: 36 W, Uoutput: 27-54 Vdc. Uout: 60 Vmax, Irated: 0.3-1 A,
tc(max): 75 °C, ta: -25 … +50 °C,
built-in, SELV

© 2026 UL LLC. All rights reserved.